

शुभ्रा = 6675  
दि० = 19/3/26


जलकल विभाग नगर निगम, वाराणसी उत्तर - प्रदेश

Water Quality Test Monitoring Report (Blanket and 15 Parameters) Month-March-2026

तहसील- राजावालाब विकास खंड - सेवापुरी

Sl. No.	Panchayat	Village	Name of Habitation	Source	Sample Date	Test Date	PH	Turb	EC	TDS	Th	Ca	Mg	Cl	Alka	Fe	NO3	F	As	Total Coll	Remark Safe or Unsafe	
01	BANAUU	BANAUULI Sewapuri	S V PUBLIC SCHOOL	SUBMIE RSIBLE	19/03 /2026	19/03 /2026	7.6	2	664	432	198	32	11.52	20	260	0.4	0	0.62	0.0	0.0	Safe	
02																						
03																						
04																						
05																						
06																						
07																						
08																						
09																						
10																						
11																						
12																						
13																						
14																						
15																						
Desirable Limit							6.5-8.5	1.0		500	200	75	30	250	200	0.3	45	1.0	.01	0.0		
Permissible limit in absence of alternate source (IS10500-2012)								NR	5.0	2000	600	200	100	1000	600	600	1.0	NR	1.5	NR		

Sample given by School Staff

Signature/Chemist  
  
 21/3/26  
 जलकल विभाग, नगर निगम  
 वाराणसी